





U.S. DEPARTMENT OF

An Overview of the Techno-Economic Valuations of Select Battery Energy Storage Projects in the Pacific Northwest

Kendall Mongird Associate Energy Research Economist

DISCOVERY

Other team members: Patrick Balducci, Vish Viswanathan, Jan Alam, Alasdair Crawford, Yong Yuan, Di Wu, Trevor Hardy

May 23, 2018





Energy Storage Projects Covered

- 1. <u>Portland General Electric</u> Salem Smart Power Center
- 2. <u>Puget Sound Energy</u> Glacier Energy Storage Project
- 3. <u>Orcas Power & Light Co-Op</u> Decatur Island Energy Storage and Community Solar Project
- 4. <u>Energy Northwest</u> Horn Rapids Solar, Storage, and Training Project





Key Concepts in Energy Storage

- Energy storage provides services or functions or values; a use case is an application specific to an installation that provides defined value to the grid and community
- Energy assets come in many forms, and these technologies must be carefully characterized
 - Photovoltaics (PV) (Solar)
 - Wind Turbines
 - Batteries
 - Hydro Resources
 - Diesel Generators
 - Power to Gas (P2G)

- Value comes in many forms
 - Bulk energy arbitrage and capacity
 - Ancillary services regulation, spin and non-spin reserve, load following, frequency response, flexible ramping, voltage support, black start
 - Transmission congestion relief and asset deferral
 - Distribution deferral, voltage support, conservation voltage regulation, and outage mitigation/resilience
 - Customer benefits demand/energy charges, reliability, demand response, resilience



Energy Storage Service Values

Energy Storage Values



Key Lesson: The value of distributed energy resources can accrue at multiple levels of the electric grid.

Individual Benefits vs. Cost Optimized Benefits



- Energy in the battery is competed for on an hourly basis
- Example: evaluated individually, the total 20-year value of Salem Smart Power Center operations exceeds \$7.5 million in present value (PV) terms. When co-optimized, revenue falls to \$5.8 million





Battery Storage Evaluation Tool (BSET)

Result							
	- Battery paramet	ters				Price select	
Pacific Northwest NATONA - ARORATORY mudy Openeed by Battelle Since 1965	Discharging efficiency: Charging efficiency: Energy capacity:		0.80654	MWh MW	Default	 All 50 prices Single price 	
			0.83594				
			16			24	
	Power capacity:		4			25	
Location		Intial SOC:	0.5			27	
Bainbridge Island		29					
Baker River 24	Prices:	.\Input\price.xlsx		Browse	30		
- Services	Balancing sig.:	.Vnput/PSE_Reserve_2020_W_1.		Browse	32 +		
	Capacity value: Deferral: Outage:	.\Input\BI\CapacityValue.xlsx		Browse			
Arbitrage		.\Input\BI\TDdeferral.xlsx		Browse	Run		
		.\Input\BI\Outage.xlsx		Browse			
Distribution deferral	Outage power:	.\Input\BI\OutagePower.xlsx			Browse	Cancel	
Planned outage	- Output	- Output					
Random outage	Output:	Brow		Browse			

There are losses associated with charging/discharging operations, which are modeled and considered in the optimal scheduling formulation in order to obtain the maximum obtainable profit

- Services/functions/values have to be co-optimized to avoid double counting
- BSET is used to run a one-year simulation of battery storage operations
- The formulation can consider the different operation modes of a hydro battery system, including:
 - Pumping (charging)
 - Generating (discharging)
 - Spinning reserve, and
 - Standby modes
- Increasing discharging power for one energy service decreases the battery's capability for other services



24-hour Energy Storage Schedule Example





(1) Portland General Electric Salem Smart Power Center (SSPC)

- Developed as an R&D project under the Pacific Northwest Smart Grid Demo as part of the American Recovery and Reinvestment Act of 2009
- The U.S. Department of Energy (DOE) provided half of the funding (\$20 million)
- 5 MW 1.25 MWh lithium-ion battery system built and managed by PGE



- Potential energy storage benefits:
 - Energy arbitrage
 - Participation in the Western Energy Imbalance Market (EIM)
 - Demand response
 - Regulation up and down
 - Primary frequency response
 - Spin reserve
 - Non-spin reserve
 - Volt-VAR control
 - Conservation voltage reduction





(1) Portland General Electric Salem Smart Power Center (cont.)

- SSPC benefits for the base case (\$5.8 million) fall far short of the revenue requirements as originally designed and built (\$28.4 million); however, the SSPC was originally designed as an R&D project with a goal of establishing a high reliability zone
- Benefit cost ratio of 0.20



Sensitivity Analyses:

- SSPC currently being used only for primary frequency response; optimal operation could generate an additional \$170,068 in value annually
- Using current day prices (Lahiri 2017)*, the loss is reduced to \$2 million overall
- Modifying the energy storage capacity greatly affects the overall return on investment ratio

*Lahiri, S. 2017. Assessing CAPEX for Storage Projects. Presentation at Storage Week. Oakland, CA.



(1) Portland General Electric Salem Smart Power Center (cont.)

By upsizing the energy storage capacity to 10 MWh, the return on investment ratio yields a positive result at 1.24



(2) Puget Sound Energy – Clean Energy Fund I Pacifi Glacier Energy Storage System



Proudly Operated by **Baffelle** Since 1965

- Frequent transmission-line outages in Glacier, WA due to vegetation
- \$3.8 million grid modernization grant awarded to Puget Sound Energy as part of Washington Clean Energy Fund (CEF) I
- 2 MW 4.4 MWh lithium-ion battery near Glacier substation to provide (temporary) backup power to distribution circuit





With DOE support, PNNL modeled battery operations to determine the long-term financial benefits and costs to Glacier, WA

Benefits Explored:

- Flexibility services
 - Energy arbitrage
 - Regulation up/down
- Primary Frequency Response
- Capacity
- Outage Mitigation

(2) Puget Sound Energy – Clean Energy Fund I Pacific Northwest Glacier Energy Storage System (cont.)



Benefit-cost ratio of 0.44



Sensitivity Analyses:

Outage Mitigation not included in base case due to utility perspective analysis. Including it increases benefits by \$2.8 million, giving a return on investment of 0.85

NATIONAL LABORATORY

Proudly Operated by Baffelle Since 1965

Extending analysis for a 20-year battery increases benefits by \$1.3 million over the life of the asset and a BCR of 0.65

(3) Orcas Power & Light Co-Op – CEF II Energy Storage & Community Solar



Proudly Operated by Baffelle Since 1965

- \$1 million grid modernization grant awarded to Orcas Power & Light Co-Op (OPALCO) as part of Washington CEF II
- 0.5 MW / 2 MWh UniEnergy Technology (UET) Vanadium Redox Flow Battery
- 504 kW LG Community Solar Array from Puget Sound Solar
- Potential PV and energy storage benefits:
 - Demand charge reduction
 - Load shaping charge reduction
 - Transmission charge reduction
 - Transmission submarine cable replacement deferral
 - Volt-VAR/CVR
 - Outage mitigation



Transmission Cable Map from Fidalgo Substation in Anacortes to Decatur and Lopez Islands



Cable 5 and ESS site at Decatur Substation in the OPALCO Single Line Diagram (left); Cable 5 Cross Section (right)

(3) Orcas Power & Light Co-Op – CEF II Energy Storage & Community Solar (cont.)



- Benefits largely driven by transmission deferral benefit at \$2.0 million in present value terms
- Cable replacement deferral estimated to be 3.65 years on a 40-year cable



Sensitivity Analyses:

Pacific Northwes

NATIONAL LABORATORY

Proudly Operated by Battelle Since 1965

Outage Mitigation not included in base case due to utility perspective analysis. Adding in the additional use case increases benefits by \$2.8 million and provides a BCR of 1.25

(4) Energy Northwest – CEF II Horn Rapids Solar, Storage, and Training Project



- \$3 million grid modernization grant awarded to Energy Northwest as part of Washington CEF II
- 1 MW 4 MWh UniEnergy Technology Vanadium Redox Flow Battery
- 4 MW Solar Array from Potelco/Quanta Services





- Potential PV and energy storage benefits:
 - Demand charge reduction
 - Load shaping charge reduction
 - Transmission charge reduction
 - Volt-VAR/CVR
 - Outage mitigation
 - Solar Energy Production
 - Renewable energy credits

(4) Energy Northwest – CEF II Horn Rapids Energy Storage Evaluation (cont.)



Proudly Operated by Battelle Since 1965

- Total 20-year value of PV and ESS operations at \$13.56 million in present value terms, while costs are \$12.87 million
- Benefit-cost ratio of 1.05



Sensitivity Analyses:

- Outage mitigation benefits are estimated at \$4.8 million in present value terms; including outage mitigation improves the benefitcost ratio to 1.43
- Net benefits of energy storage in isolation estimated at roughly (\$160k); benefit-cost ratio of .97



Comparison of Economic Results

	SSPC	Glacier	Decatur Island	Horn Rapids
Benefits	\$ 5.8 million	\$ 2.9 million	\$ 3.3 million	\$ 13.56 million
Costs	\$ 28.4 million	\$ 6.7 million	\$ 2.9 million	\$ 12.87 million
BCR	0.2	0.44	1.13	1.05

Individual Project Benefits vs Costs



Benefit Cost Ratio by Project





Conclusions

- Correctly valuing energy storage assets requires the optimal stacking of benefits. Not all benefits can be provided simultaneously, making co-optimization necessary
- Value gained from an energy storage asset can be highly dependent on site-specific factors
 - Assets that yield a positive return on investment in one location may not be economically viable in another
 - Opportunities to obtain specific benefits may not be available in all areas (i.e. arbitrage in the Pacific Northwest)
 - Technological limitations can dictate what use cases and values the asset is capable of providing
- Energy storage has the potential to provide a wide range of valuable benefits to the electric grid and the customers it serves and accurately capturing them continues to be a developing process



Acknowledgments

- Dr. Imre Gyuk Energy Storage Program Manager, Office of Electricity Delivery and Energy Reliability, U.S. Department of Energy
- Bob Kirchmeier Senior Energy Policy Specialist, Clean Energy Fund Grid Modernization Program, Washington State Energy Office